

臺北市內湖區康寧國民小學
飲水機維護紀錄表

維護日期: 108年 8月 6日
設備負責人: 總物處事務組
水源類別: 自來水

登記使用有效時間: 年 月 日 (本表請保存2年)
連絡電話: 2832-2200
設備管理人: 陳小姐

飲用水設備編號	設備設置單位		檢查 按鍵 及功 能是 否正 常	檢測 漏電 斷路 器是 否會 正常	檢查 壓縮 機及 風扇 啟動 狀況	查看 排水 是否 通暢 及是 否有	填寫 維護 紀錄 卡及 紀錄 是否	更換 纖維 濾心 (2.5. 8.11 月)	更換 碳柄 濾心 (2.5. 8.11 月)	備註
1	活動中心	1樓	✓	✓	✓	✓	✓	✓	✓	1
2	活動中心	2樓	✓	✓	✓	✓	✓	✓	✓	2
3	倫理樓	2樓	✓	✓	✓	✓	✓	✓	✓	
4	倫理樓	3樓(自然教室)	✓	✓	✓	✓	✓	✓	✓	3
5	倫理樓	3樓(靠活動中心)	✓	✓	✓	✓	✓	✓	✓	4
6	倫理樓	4樓	✓	✓	✓	✓	✓	✓	✓	
7	倫理樓	4樓	✓	✓	✓	✓	✓	✓	✓	
8	民主樓	1樓(幼黃斑)	✓	✓	✓	✓	✓	✓	✓	
9	民主樓	2樓	✓	✓	✓	✓	✓	✓	✓	5
10	民主樓	3樓	✓	✓	✓	✓	✓	✓	✓	6
11	民主樓	4樓	✓	✓	✓	✓	✓	✓	✓	7
12	民主樓	5樓	✓	✓	✓	✓	✓	✓	✓	8
13	科學樓	1樓	✓	✓	✓	✓	✓	✓	✓	
14	科學樓	1樓(健保室內)	✓	✓	✓	✓	✓	✓	✓	
15	科學樓	1樓(幼稚園)	✓	✓	✓	✓	✓	✓	✓	
16	科學樓	2樓	✓	✓	✓	✓	✓	✓	✓	9
17	科學樓	3樓	✓	✓	✓	✓	✓	✓	✓	10
18	科學樓	4樓	✓	✓	✓	✓	✓	✓	✓	
19	倫理樓	2樓	✓	✓	✓	✓	✓	✓	✓	
20	倫理樓	3樓	✓	✓	✓	✓	✓	✓	✓	
21	倫理樓	4樓	✓	✓	✓	✓	✓	✓	✓	
22	倫理樓	1樓	✓	✓	✓	✓	✓	✓	✓	
23	倫理樓	3樓	✓	✓	✓	✓	✓	✓	✓	
24	科學樓	1樓靠近操場	✓	✓	✓	✓	✓	✓	✓	
25	B1桌球		✓	✓	✓	✓	✓	✓	✓	
26	倫理3樓	乙梯	✓	✓	✓	✓	✓	✓	✓	
27	倫理4樓	乙梯	✓	✓	✓	✓	✓	✓	✓	

設備維護單位: 力霸工業科技(股)公司

電話: 2832-2200

維護人員簽章: 



設備負責人簽章: